



# ENERGY STAR<sup>®</sup> Statement of Energy Performance

# 94

ENERGY STAR<sup>®</sup>  
Score<sup>1</sup>

## Scott Hart Building

**Primary Property Function:** Office  
**Gross Floor Area (ft<sup>2</sup>):** 81,383  
**Built:** 1936

**For Year Ending:** April 30, 2013  
**Date Generated:** April 22, 2014

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

### Property & Contact Information

**Property Address**  
Scott Hart Building  
302 North Roberts  
Helena, Montana 59620

**Property Owner**  
Montana Department of Environmental  
Quality  
1520 E 6th Ave  
Helena, MT 59601-4541  
406-444-6460

**Primary Contact**  
Ronald Pecarina  
1520 E 6th Ave  
Helena, MT 59620  
4064446590  
rpecarina@mt.gov

**Property ID:** 4030103

### Energy Consumption and Energy Use Intensity (EUI)

Site EUI		Annual Energy by Fuel		National Median Comparison	
63.1 kBtu/ft <sup>2</sup>	Natural Gas (kBtu)	3,063,000	(60%)	National Median Site EUI (kBtu/ft <sup>2</sup> )	133.1
	Electric - Grid (kBtu)	2,074,090	(40%)	National Median Source EUI (kBtu/ft <sup>2</sup> )	252.1
				% Diff from National Median Source EUI	-53%
Source EUI		Annual Emissions			
119.5 kBtu/ft <sup>2</sup>		Greenhouse Gas Emissions (MtCO <sub>2</sub> e/year)		390	

### Signature & Stamp of Verifying Professional

I \_\_\_\_\_ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

#### Licensed Professional

Ronald Pecarina  
1520 E 6th Ave  
Helena, MT 59620  
4064446590  
rpecarina@mt.gov



Professional Engineer Stamp  
(if applicable)